



TVA Balancing Authority Operations

September 27, 2005

Edd Forsythe

Manager BA Operations





NERC Mission

The North American Electric Reliability
Council's (NERC's) mission is to ensure that
the bulk electric system in North America is
reliable, adequate, and secure.

NERC accomplishes this mission by:





- Setting and enforcing standards for the reliable planning and operation of the bulk electric system.
- Certifying reliability service organizations and personnel.
- Assessing the historical and near-term reliability, and future adequacy of the bulk electric system.
- Providing reliability training and education resources.
- Facilitating information exchange, system modeling, and analytical methods and tools as needed for reliability.
- Interfacing with organizations in industry and agencies of the federal, state, and provincial governments in North America on reliability matters.
- Working with industry and government to coordinate the physical and cyber security of electricity infrastructure.





 TVA Accomplishes its part in supporting the NERC mission by adhering to the following standards





- Standard INT-003-0, Section B, R1.1-4
 - Each receiving balancing authority shall confirm interchange schedules with the sending balancing authority prior to implementation in the balancing authority's ACE equation and shall agree on the following:
 - BA's that implement interchange schedules shall use the same start times and ramp duration
 - Interchange schedule start and end time
 - Energy profile
 - Ramp start and duration





Standard INT-002-0, Section B, R3

 Balancing Authorities are charged with "assessing and approving or denying the Interchange Transaction",





- Approve/deny actions of original schedule requests or modifications to existing schedules subject to:
 - NERC Policy 3, section 1.6 "Ability of generation maneuverability to accommodate the indicated energy profile (i.e. verify ramping capability, availability).
 - The new NERC Standard INT-002-0 uses this language, "Energy Profile (ability to support the magnitude of the transaction): and "Ramp (ability of generation maneuverability to accommodate)".
 - R5 in that same section of the Standards goes on to state, "shall operate such that Interchange Schedules do not knowingly cause any other systems to violate established operating criteria".





Independent Power Producer

IPP






- MONITOR REAL TIME GENERATION FROM EACH IPP
- COMPARE GENERATION TO APPROVED SCHEDULE TOTAL FOR IPP
- NOTIFY IPP & INTERCHANGE SCHEDULING OF REQUIRED ADJUSTMENT IF OUTSIDE BAND
- ENSURE ADJUSTMENT HAPPENS IN ALLOWED TIME FRAME.
- PROVIDE NECESSARY DOCUMENTATION OF ANY IMBALANCE PERIODS EXCEDING ALLOWED BAND











Loss of Generation and Schedule Adjustment





If a generation resource becomes unavailable that will prohibit the covering of a schedule, the schedule should be adjusted as soon as can be accommodated to a level equal to the instantaneous generation capability NOT what the generator will integrate for the hour. Schedule changes require a minimum of 20 minutes notice for E-Tag, but TVA will adjust the schedules sooner if the situation permits, and coordination between the source and sink can be confirmed BUT WE WILL NOT ADJUST SCHEDULES TO A TIME THAT HAS PASSED.



QUESTIONS



• ???????????